

Page 1 of 25  
Permit No.: WA-002055-9  
Issuance Date: June 25, 2004  
Effective Date: August 1, 2004  
Expiration Date: July 31, 2009

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM  
WASTE DISCHARGE PERMIT NO. WA-002055-9

STATE OF WASHINGTON  
DEPARTMENT OF ECOLOGY  
CENTRAL REGION OFFICE  
YAKIMA, WASHINGTON 98902

In compliance with the provisions of  
The State of Washington Water Pollution Control Law  
Chapter 90.48 Revised Code of Washington  
and  
The Federal Water Pollution Control Act  
(The Clean Water Act)  
Title 33 United States Code, Section 1251 et seq.

City of Pateros  
390 Lakeshore Drive  
P.O. Box 8  
Pateros, Washington 98846

<u>Plant Location:</u> 113 Lakeshore Drive Pateros, Washington 98846	<u>Receiving Water:</u> Columbia River (RM=524.1)
<u>Waterbody I.D. No.:</u> WA-CR-1040 & NN57SG	<u>Discharge Location:</u> Latitude: 48° 03' 21" N Longitude: 119° 53' 38"W
<u>Plant Type:</u> Class 2, activated sludge facility	

is authorized to discharge in accordance with the special and general conditions that follow.

---

G. Thomas Tebb, L.E.G.  
Section Manager  
Water Quality Program  
Central Region Office  
Washington State Department of Ecology

## TABLE OF CONTENTS

	<u>Page</u>
SUMMARY OF PERMIT REPORT SUBMITTALS.....	4
SPECIAL CONDITIONS.....	5
S1. DISCHARGE LIMITATIONS.....	5
A. Effluent Limitations.....	5
B. Mixing Zone Descriptions.....	5
S2. MONITORING REQUIREMENTS.....	6
A. Monitoring Schedule.....	6
B. Sampling and Analytical Procedures.....	7
C. Flow Measurement.....	7
D. Laboratory Accreditation.....	7
E. Request for Reduction of Monitoring.....	7
S3. REPORTING AND RECORDKEEPING REQUIREMENTS.....	8
A. Reporting.....	8
B. Records Retention.....	8
C. Recording of Results.....	8
D. Additional Monitoring by the Permittee.....	9
E. Noncompliance Notification.....	9
F. Maintaining a Copy of This Permit.....	9
S4. FACILITY LOADING.....	10
A. Design Criteria.....	10
B. Plans for Maintaining Adequate Capacity.....	10
C. Duty to Mitigate.....	11
D. Notification of New or Altered Sources.....	11
E. Infiltration and Inflow Evaluation.....	11
F. Wasteload Assessment.....	11
S5. OPERATION AND MAINTENANCE.....	12
A. Certified Operator.....	12
B. O & M Program.....	12
C. Short-term Reduction.....	12
D. Electrical Power Failure.....	13
E. Prevent Connection of Inflow.....	13
F. Bypass Procedures.....	13
G. O & M Manual.....	15
S6. PRETREATMENT.....	15
A. General Requirements.....	15
B. Wastewater Discharge Permit Required.....	15
C. Identification and Reporting of Existing, New, and Proposed Industrial Users.....	16
D. Duty to Enforce Discharge Prohibitions.....	16
S7. RESIDUAL SOLIDS.....	17

GENERAL CONDITIONS .....	18
G1. SIGNATORY REQUIREMENTS.....	18
G2. RIGHT OF INSPECTION AND ENTRY .....	19
G3. PERMIT ACTIONS.....	19
G4. REPORTING PLANNED CHANGES.....	20
G5. PLAN REVIEW REQUIRED .....	21
G6. COMPLIANCE WITH OTHER LAWS AND STATUTES .....	21
G7. DUTY TO REAPPLY .....	21
G8. TRANSFER OF THIS PERMIT .....	21
G9. REDUCED PRODUCTION FOR COMPLIANCE .....	22
G10. REMOVED SUBSTANCES .....	22
G11. DUTY TO PROVIDE INFORMATION.....	22
G12. OTHER REQUIREMENTS OF 40 CFR.....	22
G13. ADDITIONAL MONITORING .....	22
G14. PAYMENT OF FEES .....	23
G15. PENALTIES FOR VIOLATING PERMIT CONDITIONS .....	23
G16. UPSET .....	23
G17. PROPERTY RIGHTS.....	24
G18. DUTY TO COMPLY .....	24
G19. TOXIC POLLUTANTS.....	24
G20. PENALTIES FOR TAMPERING .....	24
G21. REPORTING ANTICIPATED NON-COMPLIANCE.....	24
G22. REPORTING OTHER INFORMATION.....	25
G23. COMPLIANCE SCHEDULES .....	25

### SUMMARY OF PERMIT REPORT SUBMITTALS

Refer to the Special and General Conditions of this permit for additional submittal requirements.

Permit Section	Submittal	Frequency	First Submittal Date
S3.	Discharge Monitoring Report (DMR)	Monthly	September 15, 2004
S3.E.	Noncompliance Notification	as necessary	as necessary
S4.B.	Plan for Maintaining Adequate Capacity	as necessary	as necessary
S4.D.	Notification of New or Altered Sources	as necessary	as necessary
S4.E.	Infiltration and Inflow Report	1/permit cycle	July 31, 2008 <sup>a</sup>
S4.F.	Wasteload Assessment	1/permit cycle	July 31, 2008 <sup>a</sup>
S5.G.	Operations and Maintenance Manual Revisions	as necessary	as necessary
G1.	Notice of Change in Authorization	as necessary	as necessary
G4.	Permit Application for Substantive Changes to the Discharge	as necessary	as necessary
G5.	Engineering Report for Construction or Modification Activities	as necessary	as necessary
G7.	Application for Permit Renewal	1/permit cycle	July 31, 2008 <sup>b</sup>

<sup>a</sup> with application for permit renewal

<sup>b</sup> One year prior to permit expiration

## SPECIAL CONDITIONS

### S1. DISCHARGE LIMITATIONS

#### A. Effluent Limitations

All discharges and activities authorized by this permit shall be consistent with the terms and conditions of this permit. The discharge of any of the following pollutants more frequently than, or at a level in excess of, that identified and authorized by this permit shall constitute a violation of the terms and conditions of this permit.

Beginning on **August 1, 2004** and lasting through **July 31, 2009** the Permittee is authorized to discharge treated municipal wastewater at Outfall # 001 subject to complying with the following limitations:

EFFLUENT LIMITATIONS <sup>1</sup> : OUTFALL #001				
Parameter	Units	Average Monthly	Average Weekly	Maximum Daily
BOD <sub>5</sub> <sup>2</sup>	mg/L; lbs/day	30; 24.6	45; 36.9	N/A
Fecal Coliform Bacteria	# colonies/100 ml	200	400	N/A
Total Suspended Solids <sup>2</sup>	mg/L; lbs/day	30; 24.6	45; 36.9	N/A
Parameter	Units	Daily Discharge Value		
pH	Standard Units	Shall not be outside the range of 6.0 to 9.0.		

<sup>1</sup> The “average monthly” and “average weekly” effluent limitations are based on the arithmetic mean of the samples taken with the exception of fecal coliform bacteria, which is based on the geometric mean. The “maximum daily” effluent limitation is the highest daily discharge value of a parameter taken over a calendar month. Each “daily discharge value” is based on the arithmetic mean of the samples taken over a single 24-hour period (i.e. calendar day).

<sup>2</sup> The average monthly effluent concentrations for BOD<sub>5</sub> and TSS shall not exceed thirty (30) mg/L **or** fifteen percent (15%) of the respective average monthly influent concentrations, whichever is more stringent.

#### B. Mixing Zone Descriptions

The maximum boundaries of the mixing zones are defined as follows:

The length of the chronic mixing zone shall extend downstream no greater than **359** feet and upstream no greater than **100** feet. The chronic mixing zone width shall be no more than **40.3** feet. The chronic and acute dilution factors were determined to be **683:1** and **37.2:1**, respectively.

## S2. MONITORING REQUIREMENTS

### A. Monitoring Schedule

Beginning on **August 1, 2004** and lasting through **July 31, 2009**, the Permittee shall monitor its wastewater according to the following schedule:

Tests	Units	Sample Point	Sampling Frequency	Sample Type
Alkalinity	mg/L as CaCO <sub>3</sub>	Final Effluent <sup>1</sup>	monthly <sup>2</sup>	24-hr. composite <sup>3</sup>
Ammonia, Total	mg/L as N	Final Effluent	monthly	24-hr. composite
BOD <sub>5</sub>	mg/L	Influent <sup>4</sup>	1/week <sup>5</sup>	24-hr. composite
		Final Effluent	1/week	24-hr. composite
BOD <sub>5</sub>	lbs/day	Influent	1/week	Calculation <sup>6</sup>
		Final Effluent	1/week	Calculation
BOD <sub>5</sub>	% Removal	Final Effluent	monthly	Calculation
Dissolved Oxygen	mg/L	Influent	1/week	Grab <sup>7</sup>
		Final Effluent	1/week	Grab
Fecal Coliform Bacteria	# colonies/100 ml	Final Effluent	1/week	Grab
Flow	mgd	Final Effluent	Daily <sup>8</sup>	Measurement
Hardness	mg/L as CaCO <sub>3</sub>	Final Effluent	monthly	24-hr. composite
pH	Standard Units	Influent	5/week <sup>9</sup>	Grab
		Final Effluent	5/week	Grab
Temperature	°C	Influent	5/week	Grab
		Final Effluent	5/week	Grab
TSS	mg/L	Influent	1/week	24-hr. composite
		Final Effluent	1/week	24-hr. composite
TSS	lbs/day	Influent	1/week	Calculation
		Final Effluent	1/week	Calculation
TSS	% removal	Final Effluent	monthly	Calculation

<sup>1</sup> "Final Effluent" means wastewater which is exiting, or has exited, the last POTW treatment operation.

<sup>2</sup> "Monthly" means one sample per calendar month.

<sup>3</sup> "24-hr. composite" means a series of, at least, four individual samples collected over a 24-hour period at selected intervals based on an increment of either flow or time, and combined into a single container to be subsequently analyzed as one sample.

<sup>4</sup> "Influent" means the raw sewage from the collection system which enters the first treatment process of the POTW.

<sup>5</sup> "1/week" means collected once during each calendar week, and exclude weekends and holidays, and on a rotational basis throughout the days of the week.

<sup>6</sup> "Calculation" means calculated using the respective sample's concentration.

<sup>7</sup> "Grab" means an individual sample collected in less than fifteen (15) minutes.

<sup>8</sup> "Daily" means collected every calendar day.

<sup>9</sup> "5/week" means collected five times during each calendar week, and exclude weekends and holidays.

**B. Sampling and Analytical Procedures**

Samples and measurements taken to meet the requirements of this permit shall be representative of the volume and nature of the monitored parameters, including representative sampling of any unusual discharge or discharge condition, including bypasses, upsets and maintenance-related conditions affecting effluent quality.

Sampling and analytical methods used to meet the monitoring requirements specified in this permit shall conform to the latest revision of the *Guidelines Establishing Test Procedures for the Analysis of Pollutants* contained in 40 CFR Part 136 or to the latest revision of *Standard Methods for the Examination of Water and Wastewater* (APHA), unless otherwise specified in this permit or approved in writing by the Department of Ecology (Department).

**C. Flow Measurement**

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the quantity of monitored flows. The devices shall be installed, calibrated, and maintained to ensure that the accuracy of the measurements are consistent with the accepted industry standard for that type of device. Frequency of calibration shall be in conformance with manufacturer's recommendations and at a minimum frequency of at least one calibration per year. Calibration records shall be maintained for at least three years.

**D. Laboratory Accreditation**

All monitoring data required by the Department shall be prepared by a laboratory registered or accredited under the provisions of, *Accreditation of Environmental Laboratories*, Chapter 173-50 WAC. Flow, temperature, settleable solids, conductivity, pH, and internal process control parameters are exempt from this requirement. Conductivity and pH shall be accredited if the laboratory must otherwise be registered or accredited.

**E. Request for Reduction of Monitoring**

The Permittee may request a reduction of the sampling frequency after twelve (12) months of monitoring. The request shall: (1) be in written form, (2) clearly state the parameters for which the reduction in monitoring is being requested, and (3) clearly state the justification for the reduction. Any request for reduction in monitoring shall be granted at the Department of Ecology's (Department) discretion and accomplished through an Administrative Order or permit modification.

### **S3. REPORTING AND RECORDKEEPING REQUIREMENTS**

The Permittee shall monitor and report in accordance with the following conditions. The falsification of information submitted to the Department shall constitute a violation of the terms and conditions of this permit.

#### **A. Reporting**

The first monitoring period begins on **August 1, 2004**. Monitoring results shall be submitted monthly. Monitoring data obtained during each monitoring period shall be summarized, reported, and submitted on a Discharge Monitoring Report (DMR) form provided, or otherwise approved, by the Department. DMR forms shall be received by the Department no later than the 15th day of the month following the completed monitoring period, unless otherwise specified in this permit.

The report(s) shall be sent to:

Permit Data Systems Manager  
Department of Ecology  
Central Regional Office  
15 West Yakima Avenue, Suite 200  
Yakima, Washington 98902

Discharge Monitoring Report forms must be submitted monthly whether or not the facility was discharging. If there was no discharge during a given monitoring period, submit the form as required with the words "no discharge" entered in place of the monitoring results.

#### **B. Records Retention**

The Permittee shall retain records of all monitoring information for a minimum of three (3) years. Such information shall include all calibration and maintenance records and all original recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit. This period of retention shall be extended during the course of any unresolved litigation regarding the discharge of pollutants by the Permittee or when requested by the Department.

#### **C. Recording of Results**

For each measurement or sample taken, the Permittee shall record the following information: (1) the date, exact place, method, and time of sampling or measurement;



(2) the individual who performed the sampling or measurement; (3) the dates the analyses were performed; (4) the individual who performed the analyses; (5) the analytical techniques or methods used; and (6) the results of all analyses.

**D. Additional Monitoring by the Permittee**

If the Permittee monitors any pollutant more frequently than required by this permit using test procedures specified by Special Condition S2 of this permit, then the results of such monitoring shall be included in the calculation and reporting of the data submitted in the Permittee's DMR.

**E. Noncompliance Notification**

In the event the Permittee is unable to comply with any of the terms and conditions of this permit due to any cause, the Permittee shall:

1. Immediately take action to stop, contain, and cleanup unauthorized discharges or otherwise stop the noncompliance, correct the problem and, if applicable, repeat sampling and analysis of any noncompliance immediately and submit the results to the Department within (30) days after becoming aware of the violation.
2. Immediately notify the Department of the failure to comply.
3. Submit a detailed written report to the Department within thirty (30) days (five [5] days for upsets and bypasses), unless requested earlier by the Department. The report shall contain a description of the noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

Compliance with these requirements does not relieve the Permittee from responsibility to maintain continuous compliance with the terms and conditions of this permit or the resulting liability for failure to comply.

**F. Maintaining a Copy of This Permit**

A copy of this permit must be kept at the treatment plant and be made available upon request to the public or Ecology inspectors.

#### **S4. FACILITY LOADING**

##### **A. Design Criteria**

Flows or waste loadings of the following design criteria for the permitted treatment facility shall not be exceeded:

<b>Parameter</b>	<b>Design Quantity</b>
Monthly average flow (max. month):	0.0983 mgd
BOD <sub>5</sub> influent loading:	233 lbs/day
TSS influent loading:	288 lbs/day

##### **B. Plans for Maintaining Adequate Capacity**

The Permittee shall submit to the Department a plan and a schedule for continuing to maintain capacity when:

1. The actual flow or wasteload reaches 85 percent of any one of the design criteria in S4.A for three (3) consecutive months; or
2. When the projected increase would reach design capacity within five (5) years, whichever occurs first. If such a plan is required, it shall contain a plan and schedule for continuing to maintain capacity. The capacity as outlined in this plan must be sufficient to achieve the effluent limitations and other conditions of this permit.

This plan shall address the following actions or any others necessary to meet the objective of maintaining capacity.

- a. Analysis of the present design including the introduction of any process modifications that would establish the ability of the existing facility to achieve the effluent limits and other requirements of this permit at specific levels in excess of the existing design criteria specified in paragraph A above.
- b. Reduction or elimination of excessive infiltration and inflow of uncontaminated ground and surface water into the sewer system.
- c. Limitation on future sewer extensions or connections or additional waste loads.
- d. Modification or expansion of facilities necessary to accommodate increased flow or waste load.

- e. Reduction of industrial or commercial flows or wasteloads to allow for increasing sanitary flow or waste load.

Engineering documents associated with the plan must meet the requirements of WAC 173-240-060, "Engineering Report," and be approved by the Department prior to any construction. The plan shall specify any contracts, ordinances, methods for financing, or other arrangements necessary to achieve this objective.

#### **C. Duty to Mitigate**

The Permittee is required to take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit that has a reasonable likelihood of adversely affecting human health or the environment

#### **D. Notification of New or Altered Sources**

The Permittee shall submit written notice to the Department whenever any new discharge or a substantial change in volume or character of an existing discharge into the POTW is proposed which: (1) would interfere with the operation of, or exceed the design capacity of, any portion of the POTW; (2) is not part of an approved general sewer plan or approved plans and specifications; or (3) would be subject to pretreatment standards under 40 CFR Part 403 and Section 307(b) of the Clean Water Act. This notice shall include an evaluation of the POTW's ability to adequately transport and treat the added flow and/or waste load, the quality and volume of effluent to be discharged to the POTW, and the anticipated impact on the Permittee's effluent [40 CFR 122.42(b)].

#### **E. Infiltration and Inflow Evaluation**

1. The Permittee shall conduct an infiltration and inflow evaluation. Refer to the U.S. EPA publication, *I/I Analysis and Project Certification*, available as Publication No. 97-03 at: Publications Office, Department of Ecology, PO Box 47600, Olympia, WA, 98504-7600. Plant monitoring records may be used to assess measurable infiltration and inflow.
2. The report shall be submitted by **July 31, 2008**.

#### **F. Wasteload Assessment**

The Permittee shall conduct an assessment of its flow and wasteload and submit a report to the Department by **July 31, 2008**. The report shall contain the following: an indication of compliance or noncompliance with the permit effluent limitations; a

comparison between the existing and design monthly average dry weather and wet weather flows, peak flows, BOD, and total suspended solids loadings; and the percentage increase in these parameters since the previous report. The report shall also state the present and design population or population equivalent, projected population growth rate, and the estimated date upon which the design capacity is projected to be reached, according to the most restrictive of the parameters above. The interval for review and reporting may be modified if the Department determines that a different frequency is sufficient.

## **S5. OPERATION AND MAINTENANCE**

The Permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance (O&M) also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems, which are installed by a Permittee only when the operation is necessary to achieve compliance with the conditions of this permit.

### **A. Certified Operator**

An operator certified by the State for, at least, a Class II wastewater treatment plant shall be in responsible charge of the day-to-day operation of the POTW. An operator certified by the State for, at least, a Class I wastewater treatment plant shall be present at the POTW during all shifts when operational changes are made to the wastewater treatment process.

### **B. O & M Program**

The Permittee shall institute an adequate (O&M) program for the entire sewage system. Maintenance records shall be maintained on all major electrical and mechanical components of the treatment plant, as well as the sewage system and pumping stations. Such records shall clearly specify the frequency and type of maintenance recommended by the manufacturer and shall show the frequency and type of maintenance performed. These maintenance records shall be available for inspection at all times.

### **C. Short-term Reduction**

If a Permittee contemplates a reduction in the level of treatment that would cause a violation of permit discharge limitations on a short-term basis for any reason, and such reduction cannot be avoided, the Permittee shall give written notification to the Department, if possible, thirty (30) days prior to such activities, detailing the reasons

for, length of time of, and the potential effects of the reduced level of treatment. This notification does not relieve the Permittee of its obligations under this permit.

**D. Electrical Power Failure**

The Permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated wastes or wastes not treated in accordance with the requirements of this permit during electrical power failure at the treatment plant and/or sewage lift stations either by means of alternate power sources, standby generator, or retention of inadequately treated wastes.

The Permittee shall maintain Reliability Class II (EPA 430-99-74-001) at the wastewater treatment plant, which requires a backup power source sufficient to operate all vital components and critical lighting and ventilation during peak wastewater flow conditions, except vital components used to support the secondary processes (i.e., mechanical aerators or aeration basin air compressors) need not be operable to full levels of treatment, but shall be sufficient to maintain the biota.

**E. Prevent Connection of Inflow**

The Permittee shall strictly enforce its sewer ordinances and not allow the connection of inflow (roof drains, foundation drains, etc.) to the sanitary sewer system.

**F. Bypass Procedures**

Bypass, which is the intentional diversion of waste streams from any portion of a treatment facility, is prohibited, and the Department may take enforcement action against a Permittee for bypass unless one of the following circumstances (1, 2, or 3) is applicable.

1. Bypass for essential maintenance without the potential to cause violation of permit limits or conditions.

Bypass is authorized if it is for essential maintenance and does not have the potential to cause violations of limitations or other conditions of this permit, or adversely impact public health as determined by the Department prior to the bypass. The Permittee shall submit prior notice, if possible at least ten (10) days before the date of the bypass.

2. Bypass which is unavoidable, unanticipated and results in noncompliance of this permit.

This bypass is permitted only if:

- a. Bypass is unavoidable to prevent loss of life, personal injury, or severe property damage. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass.
  - b. There are no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, stopping production, maintenance during normal periods of equipment downtime (but not if adequate backup equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance), or transport of untreated wastes to another treatment facility.
  - c. The Department is properly notified of the bypass as required in Special Condition S3.E of this permit.
3. Bypass which is anticipated and has the potential to result in noncompliance of this permit

The Permittee shall notify the Department at least thirty (30) days before the planned date of bypass. The notice shall contain: (1) a description of the bypass and its cause; (2) an analysis of all known alternatives which would eliminate, reduce, or mitigate the need for bypassing; (3) a cost-effectiveness analysis of alternatives including comparative resource damage assessment; (4) the minimum and maximum duration of bypass under each alternative; (5) a recommendation as to the preferred alternative for conducting the bypass; (6) the projected date of bypass initiation; (7) a statement of compliance with SEPA; (8) a request for modification of water quality standards as provided for in WAC 173-201A-110, if an exceedance of any water quality standard is anticipated; and (9) steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass.

For probable construction bypasses, the need to bypass is to be identified as early in the planning process as possible. The analysis required above shall be considered during preparation of the engineering report or facilities plan and plans and specifications and shall be included to the extent practical. In cases where the probable need to bypass is determined early, continued analysis is necessary up to and including the construction period in an effort to minimize or eliminate the bypass.

The Department will consider the following prior to issuing an administrative order for this type bypass:

- a. If the bypass is necessary to perform construction or maintenance-related activities essential to meet the requirements of this permit.
- b. If there are feasible alternatives to bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, stopping production, maintenance during normal periods of equipment down time, or transport of untreated wastes to another treatment facility.
- c. If the bypass is planned and scheduled to minimize adverse effects on the public and the environment.

After consideration of the above and the adverse effects of the proposed bypass and any other relevant factors, the Department will approve or deny the request. The public shall be notified and given an opportunity to comment on bypass incidents of significant duration, to the extent feasible. Approval of a request to bypass will be by administrative order issued by the Department under RCW 90.48.

#### **G. O & M Manual**

The approved O&M Manual shall be kept available at the treatment plant and all operators shall follow the instructions and procedures of this manual.

The O&M Manual shall be reviewed by the Permittee at least annually. Substantial changes or updates to the O&M Manual shall be submitted to the Department whenever they are incorporated into the manual.

### **S6. PRETREATMENT**

#### **A. General Requirements**

The Permittee shall work with the Department to ensure that all commercial and industrial users of the publicly owned treatment works (POTW) are in compliance with the pretreatment regulations promulgated in 40 CFR Part 403 and any additional regulations that may be promulgated under Section 307(b) (pretreatment) and 308 (reporting) of the Federal Clean Water Act.

#### **B. Wastewater Discharge Permit Required**

The Permittee shall not allow significant industrial users (SIUs) to discharge wastewater to the Permittee's sewerage system until such user has received a wastewater discharge permit from the Department in accordance with Chapter 90.48 RCW and Chapter 173-216 WAC, as amended.

**C. Identification and Reporting of Existing, New, and Proposed Industrial Users**

1. The Permittee shall take continuous, routine measures to identify all existing, new, and proposed SIUs and potential significant industrial users (PSIUs) discharging or proposing to discharge to the Permittee's sewerage system (see Appendix B of Fact Sheet for definitions).
2. Within thirty (30) days of becoming aware of an unpermitted existing, new, or proposed industrial user who may be an SIU, the Permittee shall notify such user by registered mail that, if classified as an SIU, they shall be required to apply to the Department and obtain a State Waste Discharge Permit. A copy of this notification letter shall also be sent to the Department within this same 30-day period.
3. The Permittee shall also notify all PSIUs, as they are identified, that if their classification should change to an SIU, they shall be required to apply to the Department for a State Waste Discharge Permit within thirty (30) days of such change.

**D. Duty to Enforce Discharge Prohibitions**

1. In accordance with 40 CFR 403.5(a), the Permittee shall not authorize or knowingly allow the discharge of any pollutants into its POTW which cause pass through or interference, or which otherwise violates general or specific discharge prohibitions contained in 40 CFR 403.5 or WAC-173-216-060.
2. The Permittee shall not authorize or knowingly allow the introduction of any of the following into the its POTW:
  - a. Pollutants which create a fire or explosion hazard in the POTW (including, but not limited to waste streams with a closed cup flashpoint of less than 140 degrees Fahrenheit or 60 degrees Centigrade using the test methods specified in 40 CFR 261.21).
  - b. Pollutants which will cause corrosive structural damage to the POTW, but in no case discharges with pH lower than 5.0, or greater than 11.0 standard units, unless the works are specifically designed to accommodate such discharges.
  - c. Solid or viscous pollutants in amounts that could cause obstruction to the flow in sewers or otherwise interfere with the operation of the POTW.
  - d. Any pollutant, including oxygen demanding pollutants, (BOD, etc.) released in a discharge at a flow rate and/or pollutant concentration which will cause interference with the POTW.



- e. Petroleum oil, nonbiodegradable cutting oil, or products of mineral origin in amounts that will cause interference or pass through.
  - f. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity which may cause acute worker health and safety problems.
  - g. Heat in amounts that will inhibit biological activity in the POTW resulting in interference but in no case heat in such quantities such that the temperature at the POTW headworks exceeds 40°C (104°F) unless the Department, upon request of the Permittee, approves, in writing, alternate temperature limits.
  - h. Any trucked or hauled pollutants, except at discharge points designated by the Permittee.
  - i. Wastewaters prohibited to be discharged to the POTW by the Dangerous Waste Regulations (Chapter 173-303 WAC), unless authorized under the Domestic Sewage Exclusion (WAC 173-303-071).
3. All of the following are prohibited from discharge to the POTW unless approved in writing by the Department under extraordinary circumstances (such as a lack of direct discharge alternatives due to combined sewer service or the need to augment sewage flows due to septic conditions):
- a. Noncontact cooling water in significant volumes.
  - b. Stormwater and other direct inflow sources.
  - c. Wastewaters significantly affecting system hydraulic loading, which do not require treatment, or would not be afforded a significant degree of treatment by the system.
4. The Permittee shall notify the Department if any industrial user violates the prohibitions listed in this section.

## **S7. RESIDUAL SOLIDS**

Residual solids include screenings, grit, scum, and other solid waste. The Permittee shall store and handle all residual solids in such a manner so as to prevent their entry into State ground or surface waters. The Permittee shall not discharge leachate from residual solids to waters of the State. The Permittee shall comply with all applicable local (Okanogan Health District), State (Chapter 173-308 WAC) and Federal (40 CFR Part 503) regulations concerning the disposal of solid waste and biosolids.

## GENERAL CONDITIONS

### G1. SIGNATORY REQUIREMENTS

All applications, reports, or information submitted to the Department shall be signed and certified.

- A. All permit applications shall be signed by either a principal executive officer or a ranking elected official.
- B. All reports required by this permit and other information requested by the Department shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - 1. The authorization is made in writing by a person described above and submitted to the Department.
  - 2. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.)
- C. Changes to authorization. If an authorization under paragraph B.2 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph B.2 above must be submitted to the Department prior to or together with any reports, information, or applications to be signed by an authorized representative.
- D. Certification. Any person signing a document under this section shall make the following certification:

I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false

information, including the possibility of fine and imprisonment for knowing violations.

## **G2. RIGHT OF INSPECTION AND ENTRY**

The Permittee shall allow an authorized representative of the Department, upon the presentation of credentials and such other documents as may be required by law:

- A. To enter upon the premises where a discharge is located or where any records must be kept under the terms and conditions of this permit.
- B. To have access to and copy - at reasonable times and at reasonable cost - any records required to be kept under the terms and conditions of this permit.
- C. To inspect - at reasonable times - any facilities, equipment (including monitoring and control equipment), practices, methods, or operations regulated or required under this permit.
- D. To sample or monitor - at reasonable times - any substances or parameters at any location for purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act.

## **G3. PERMIT ACTIONS**

This permit may be modified, revoked and reissued, or terminated either at the request of any interested person (including the permittee) or upon the Department's initiative. However, the permit may only be modified, revoked and reissued, or terminated for the reasons specified in 40 CFR 122.62, 122.64 or WAC 173-220-150 according to the procedures of 40 CFR 124.5.

- A. The following are causes for terminating this permit during its term, or for denying a permit renewal application:
  - 1. Violation of any permit term or condition.
  - 2. Obtaining a permit by misrepresentation or failure to disclose all relevant facts.
  - 3. A material change in quantity or type of waste disposal.
  - 4. A determination that the permitted activity endangers human health or the environment, or contributes to water quality standards violations and can only be regulated to acceptable levels by permit modification or termination [40 CFR part 122.64(3)].
  - 5. A change in any condition that requires either a temporary or permanent reduction, or elimination of any discharge or sludge use or disposal practice controlled by the permit [40 CFR part 122.64(4)].

6. Nonpayment of fees assessed pursuant to RCW 90.48.465.
  7. Failure or refusal of the permittee to allow entry as required in RCW 90.48.090.
- B. The following are causes for modification but not revocation and reissuance except when the permittee requests or agrees:
1. A material change in the condition of the waters of the State.
  2. New information not available at the time of permit issuance that would have justified the application of different permit conditions.
  3. Material and substantial alterations or additions to the permitted facility or activities which occurred after this permit issuance.
  4. Promulgation of new or amended standards or regulations having a direct bearing upon permit conditions, or requiring permit revision.
  5. The Permittee has requested a modification based on other rationale meeting the criteria of 40 CFR part 122.62.
  6. The Department has determined that good cause exists for modification of a compliance schedule, and the modification will not violate statutory deadlines.
  7. Incorporation of an approved local pretreatment program into a municipality's permit.
- C. The following are causes for modification or alternatively revocation and reissuance:
1. Cause exists for termination for reasons listed in A1 through A7 of this section, and the Department determines that modification or revocation and reissuance is appropriate.
  2. The Department has received notification of a proposed transfer of the permit. A permit may also be modified to reflect a transfer after the effective date of an automatic transfer (General Condition G8) but will not be revoked and reissued after the effective date of the transfer except upon the request of the new permittee.

#### **G4. REPORTING PLANNED CHANGES**

The Permittee shall, as soon as possible, but no later than sixty (60) days prior to the proposed changes, give notice to the Department of planned physical alterations or additions to the permitted facility, production increases, or process modification which will result in:

- 1) the permitted facility being determined to be a new source pursuant to 40 CFR 122.29(b);
- 2) a significant change in the nature or an increase in quantity of pollutants discharged; or
- 3) a significant change in the Permittee's sludge use or disposal practices.

Following such notice, and the submittal of a new application or supplement to the existing application, along with required engineering plans and reports, this permit may be modified, or revoked and reissued pursuant to 40 CFR 122.62(a) to specify and limit any pollutants not previously limited. Until such modification is effective, any new or increased discharge in excess of

permit limits or not specifically authorized by this permit constitutes a violation of the terms and conditions of this permit.

#### **G5. PLAN REVIEW REQUIRED**

Prior to constructing or modifying any wastewater control facilities, an engineering report and detailed plans and specifications shall be submitted to the Department for approval in accordance with Chapter 173-240 WAC. Engineering reports, plans, and specifications shall be submitted at least one hundred eighty (180) days prior to the planned start of construction unless a shorter time is approved by Ecology. Facilities shall be constructed and operated in accordance with the approved plans.

#### **G6. COMPLIANCE WITH OTHER LAWS AND STATUTES**

Nothing in this permit shall be construed as excusing the Permittee from compliance with any applicable Federal, State, or local statutes, ordinances, or regulations.

#### **G7. DUTY TO REAPPLY**

The Permittee shall apply for permit renewal at least one (1) year prior to the specified expiration date of this permit.

#### **G8. TRANSFER OF THIS PERMIT**

In the event of any change in control or ownership of facilities from which the authorized discharge emanate, the Permittee shall notify the succeeding owner or controller of the existence of this permit by letter, a copy of which shall be forwarded to the Department.

##### **A. Transfers by Modification**

Except as provided in paragraph (B) below, this permit may be transferred by the Permittee to a new owner or operator only if this permit has been modified or revoked and reissued under 40 CFR 122.62(b)(2), or a minor modification made under 40 CFR 122.63(d), to identify the new Permittee and incorporate such other requirements as may be necessary under the Clean Water Act.

##### **B. Automatic Transfers**

This permit may be automatically transferred to a new Permittee if:

1. The Permittee notifies the Department at least thirty (30) days in advance of the proposed transfer date.

2. The notice includes a written agreement between the existing and new Permittees containing a specific date transfer of permit responsibility, coverage, and liability between them.
3. The Department does not notify the existing Permittee and the proposed new Permittee of its intent to modify or revoke and reissue this permit. A modification under this subparagraph may also be minor modification under 40 CFR 122.63. If this notice is not received, the transfer is effective on the date specified in the written agreement.

#### **G9. REDUCED PRODUCTION FOR COMPLIANCE**

The Permittee, in order to maintain compliance with its permit, shall control production and/or all discharges upon reduction, loss, failure, or bypass of the treatment facility until the facility is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power of the treatment facility is reduced, lost, or fails.

#### **G10. REMOVED SUBSTANCES**

Collected screenings, grit, solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters shall not be resuspended or reintroduced to the final effluent stream for discharge to State waters.

#### **G11. DUTY TO PROVIDE INFORMATION**

The Permittee shall submit to the Department, within a reasonable time, all information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The Permittee shall also submit to the Department upon request, copies of records required to be kept by this permit.

#### **G12. OTHER REQUIREMENTS OF 40 CFR**

All other requirements of 40 CFR 122.41 and 122.42 are incorporated in this permit by reference.

#### **G13. ADDITIONAL MONITORING**

The Department may establish specific monitoring requirements in addition to those contained in this permit by administrative order or permit modification.

**G14. PAYMENT OF FEES**

The Permittee shall submit payment of fees associated with this permit as assessed by the Department.

**G15. PENALTIES FOR VIOLATING PERMIT CONDITIONS**

Any person who is found guilty of willfully violating the terms and conditions of this permit shall be deemed guilty of a crime, and upon conviction thereof shall be punished by a fine of up to ten thousand dollars (\$10,000) and costs of prosecution, or by imprisonment in the discretion of the court. Each day upon which a willful violation occurs may be deemed a separate and additional violation.

Any person who violates the terms and conditions of a waste discharge permit shall incur, in addition to any other penalty as provided by law, a civil penalty in the amount of up to ten thousand dollars (\$10,000) for every such violation. Each and every such violation shall be a separate and distinct offense, and in case of a continuing violation, every day's continuance shall be deemed to be a separate and distinct violation.

**G16. UPSET**

Definition – “Upset” means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of the following paragraph are met.

A Permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that: 1) an upset occurred and that the Permittee can identify the cause(s) of the upset; 2) the permitted facility was being properly operated at the time of the upset; 3) the Permittee submitted notice of the upset as required in Special Condition S3.E; and 4) the Permittee complied with any remedial measures required under Special Condition S4.C of this permit.

In any enforcement proceeding the Permittee seeking to establish the occurrence of an upset has the burden of proof.

**G17. PROPERTY RIGHTS**

This permit does not convey any property rights of any sort, or any exclusive privilege.

**G18. DUTY TO COMPLY**

The Permittee shall comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

**G19. TOXIC POLLUTANTS**

The Permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if this permit has not yet been modified to incorporate the requirement.

**G20. PENALTIES FOR TAMPERING**

The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than ten thousand dollars (\$10,000) per violation, or by imprisonment for not more than two years per violation, or by both. If a conviction of a person is for a violation committed after a first conviction of such person under this Condition, punishment shall be a fine of not more than twenty thousand dollars (\$20,000) per day of violation, or by imprisonment of not more than four (4) years, or by both.

**G21. REPORTING ANTICIPATED NON-COMPLIANCE**

The Permittee shall give advance notice to the Department by submission of a new application or supplement thereto at least one hundred and eighty (180) days prior to commencement of such discharges, of any facility expansions, production increases, or other planned changes, such as process modifications, in the permitted facility or activity which may result in noncompliance with permit limits or conditions. Any maintenance of facilities, which might necessitate unavoidable interruption of operation and degradation of effluent quality, shall be scheduled during noncritical water quality periods and carried out in a manner approved by the Department.



**G22. REPORTING OTHER INFORMATION**

Where the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to the Department, it shall promptly submit such facts or information.

**G23. COMPLIANCE SCHEDULES**

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than fourteen (14) days following each schedule date.